

**1993 COMPLIANCE REPORT
FOR
THE HAMLET OF AKLAVIK
WATER LICENCE N3L4-0570**

Prepared By:

SCOTT GALLUPE

INSPECTOR UNDER THE NORTHWEST TERRITORIES WATERS ACT

NORTHERN AFFAIRS PROGRAM

INDIAN AND NORTHERN AFFAIRS CANADA

INUVIK, NT

MAY 1994

**HAMLET OF AKLAVIK
WATER LICENCE N3L4-0570
1993 COMPLIANCE REPORT**

INTRODUCTION

This report covers the Hamlet of Aklavik's compliance with their Water Licence N3L4-0570 for the 1993 calendar year.

The scope of this Licence allows for municipal water use and waste disposal at Aklavik, Northwest Territories. Aklavik's Water Licence N3L4-0570 became effective May 1, 1989 and expires April 30, 1999.

INSPECTIONS

An inspection of Aklavik's water and waste disposal facilities was conducted on October 5, 1993, by Scott Gallupe, Water Resources Officer, Inuvik. The contact people for the inspection were Nellie Gruben, Senior Administrative Officer and Richard Ross, Hamlet Foreman.

WATER LICENCE N3L4-0570 1993 COMPLIANCE REVIEW

Part A: General Conditions

Item 10 states: "The Licensee shall, within sixty (60) days of the issuance of this Licence, post signs in the area of the water supply facilities and in the areas of the waste disposal facilities to advise the public that these areas are being used for the municipal water supply and for the disposal of municipal wastes. All postings shall be located and maintained to the satisfaction of the Inspector."

Violations: The Hamlet of Aklavik was in non-compliance with this requirement at time of inspection October 5, 1993.

Comment: The honey bag pit sign should be adjacent to the excavation pit and the solid waste disposal site sign should be repaired to clearly identify the facility.

Part B: Conditions Applying to Water Use

No violations were noted under this section of Water Licence N3L4-0570 for the 1993 calendar year.

Part C: Conditions Applying to Waste Disposal

No violations were noted under this section of Water Licence N3L4-0570 for the 1993 calendar year.

Part D: Conditions Applying to Modifications

No violations were noted under this section of Water Licence N3L4-0570 for the 1993 calendar year.

SURVEILLANCE NETWORK PROGRAM

Part B: Sampling and Analysis Requirements

Item 1 states: "The effluent at Station 570-3 shall be sampled once immediately after break-up of the Clearing Lake Sewage Lagoon and once prior to freeze-up."

Violation: No sample was taken prior to freeze-up in 1993.

Part C: Flow Measurement and Recording Requirements

No violations were noted under this section of Water Licence N3L4-0570 for the 1993 calendar year.


Part D: Reports

No violations were noted under this section of Water Licence N3L4-0570 for the 1993 calendar year.

Comment: The late submission of the 1992 Annual Report (October 21, 1993) was reported as a violation in the 1992 Compliance Report.

Other Concerns

No other concerns were noted regarding compliance with Water Licence N3L4-0570 for the 1993 calendar year.


Scott Gallupe
Water Resources Officer