



MUNICIPAL WATER USE INSPECTION FORM

DATE: November 19, 1996 COMPANY REP.: Richard Ross / Elizabeth Kwanice
LICENSEE: Hamlet of AKLAVIK LICENCE #: N3L4-0570

WATER SUPPLY

Source (s): Mackenzie River, Peel Channel Quantity Used (to date): UNKNOWN
Owner/Operator: Owner = GNWT; Operator = GNWT (estimate or actual)

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable

Intake Facilities: A Storage Structure A Treatment Systems A Chem. Storage A
Flow Meas. Device A Convey. Lines N/A Pumping Stations A

Comments: Note: In order to prevent cross contamination, the facility should be kept neat and tidy.

WASTE DISPOSAL

Sewage Sewage Treatment System (primary, secondary or tertiary) Primary
Natural Water body Continuous Discharge (land or water)
Seasonal Discharge _____ Wetlands Treatment _____ Trench _____
Solid Waste: Owner/Operator: Owner = GNWT Operator = Hamlet
Landfill _____ Burn & Landfill Other _____

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable

Disch. Quality A Decant Structure N/A Erosion N/A
Disch. Meas. Dev. A Dyke Inspection N/A Seepages N/A
Dams, Dykes A Freeboard N/A Spills N/A
Construcion A O & M Plan A A & R Plan N/A
Periods of Discharge: A Effluent Discharge Rate: _____

Comments: SNP station not posted. Please place a SNP sign at station SNP 570-3.
Solid waste disposal site was partially fenced.

FUEL STORAGE

Owner: _____ Operator _____ Condition of Tanks _____
Berms & Liners _____ Water within berm: N/A Evidence of Leaks: _____
Drainage Pipes _____ Pump Station and Catchment Berm _____
Pipeline Condition _____ Not Applicable: _____

SURVEILLANCE NETWORK PROGRAM

Samples Collected: (Hamlet) October 15, 1996 - sample mix up. No BODs and bacteri bottle taken.
(DIAND) November 19, 1996

Signs Posted: SNP Only SNP 570-1, the others were not. Warning Yes.

Record & Reporting Acceptable, except for the lack of information in the annual report. The annual report was explained to the Assistant S.A.O.

Geotechnical Inspection: _____

Non-Compliance of Act or Licence: Violations: 1. Part A, Item 9: SNP 570-3 and 570-4 were not posted.

Page 2 attached Yes _____ No X

A SENIOR ADMIN. OFFICER.

Licensee Representatives Title

E. Hennig
Licensee Representatives Signature

SCOTT GALLUPE / Allen Kogiak

Inspectors Name

[Signature]
Inspectors Signature