



GOVERNMENT OF THE NORTHWEST
TERRITORIES
CANADA


Department of Indian &
Northern Affairs
Northern Operations Branch

JUL 30 1979

WATER MANAGEMENT
YELLOWKNIFE, N.W.T.,
1979

N3L40570

Mr. Bob Hale,
Controller,
N.W.T. Water Board,
P.O. Box 1500,
YELLOWKNIFE, N.W.T.
X1A 2R3.



Dear Mr. Hale:

Re: Application for Water Licence
Hamlet of Aklavik

The following information is presented as an update to the original water licence application dated January 25, 1977. Please consider this application as being jointly submitted by the Hamlet and by the G.N.W.T. since the latter is responsible for the capital cost and the O/M of the water/sewer infrastructure. The Water Licence should reflect the joint nature of this application.

Water Supply:

A description of the existing water supply system and the planned changes to this system is included in the enclosed report entitled "Aklavik Water Supply" dated February, 1979 (only one copy is available at this time). Briefly, the planned changes entail the installation of a permanent intake to the Peel Channel of the Mackenzie River, a package "water boy" treatment plant and a flocculator/tube settler. The "Water Boy" unit has already been installed and is operating satisfactorily. Scheduled completion date for installation of the permanent intake and the flocculator/tube settler is late September of this year. Hamlet approval of this system, which enables year round pumping from the River, is shown in the attached Council minutes dated February 6, 1979. Continued use of the summer distribution lines is being considered.

A copy of the engineering drawings entitled "Modifications to Water Treatment Plant and Intake Installation, Project No. 77-038" dated April, 1979 is also included for your use. Sepias of these drawings will be forwarded within one week.


Waste Disposal:

Sewage pumpout and honeybags are disposed of at the

dump located just northwest of the end of the airstrip on the west side of the road. Current plans are for the construction of improved sewage treatment/disposal facilities during 1981 and 1982, subject to availability of funding. Studies regarding these improvements will be forwarded to you when available.

Please contact this office if presentation to either the Technical Committee or the Water Board is required in support of the application. Any other response by your offices concerning this application should also be directed to the Water and Sanitation Section. The one exception to this is that Ron Yaworski, D.P.W., should be contacted regarding any further technical information required. His phone number is 873-7835.

Yours truly,



V. Christensen,
Head,
Water & Sanitation Section,
Town Planning & Lands Division,
Department of Local Government.

Attachment

c.c.: Mr. Ron Yaworski,
Department of Public Works.

c.c.: Secretary Manager,
Hamlet of Aklavik,
AKLAVIK, N.W.T.

N3L 40570

REGULAR MEETING

Tuesday, February 6, 1979

Absent: Mayor Tornow, Councillors McLeod, T. Arey, B. Storr, R. Arey F. Elank.

Absent: Deputy Mayor Hansen and Councillor Carmichael

Minutes: Moved by Councillor McLeod that the minutes of meeting #3/79 be adopted as circulated.

Seconded by Councillor R. Arey

Carried

#21/79

Requests, Complaints & Delegations:

- Fred James from D.P.W. talked with Council on the water system in Aklavik. The present summer lake is contaminated and definitely cannot be used this summer.

Ways were studied on the best summer water system. The most economical way was to put in a filtering system in the new treatment plant and pump from the river year round. Council were all in favor of pumping from the river year round.

The next problem will be to get the filtering system to Inuvik. Here was mentioned then from Inuvik to Aklavik was no problem as the winter road could be used. The filtering system will have to be in before spring as the river plant will have to be used.

Fred James said that a letter should be in in about 10 days with an answer on whether or not the filtering system will be able to get to Inuvik.

- Joan Woodside addressed Council on behalf of the alcohol committee. There is funding available for a member on the committee to take training on alcohol counselling. She requested a letter be written supporting the proposal also she asked for office space for this person.

Moved by Councillor T. Arey that a letter be written to Al Wilson to support the proposal of the Aklavik Alcohol committee to send someone for training to be an alcohol councillor.

Seconded by Councillor Storr

Carried

#22/79

Moved by Councillor McLeod that a letter be written to D.P.W. asking for the use of the old court worker's office.

Seconded by Councillor Storr

Carried

#23/79

Reports Recreation Directors report was reviewed by Council.

Letters Letter from school principal on damages caused by people using the gym on sports nights. Council decided that the Drop In Centre person help the recreation director to watch the school.

4377
N2L4-0570

Department of Indian &
Northern Affairs
Northern Operations Branch

JUL 30 1979

WATER MANAGEMENT
YELLOWKNIFE, N.W.T.



AKLAVIK

WATER

SUPPLY

PROJECT 77-038

78140570

R.A. Yaworsky
Engineering Division
Dept. of Public Works
Government of the N.W.T.
February 1979

INTRODUCTION

Aklavik, located at the junction of the Enock, Pokiak and Peel Channels of the Mackenzie River, is approximately 180 km north of the Arctic Circle and 80 km south of Mackenzie Bay on the Beaufort Sea. As such, the settlement is in the west central portion of the Mackenzie Delta which is one of the largest deltas in the world extending 230 km from its head at Point Separation to its mouth at the Arctic Ocean, and at its widest point measuring some 160 km. The delta itself is a maze of river channels, islands and lakes. On one side the Mackenzie is bordered by a range of hills and on the other side the Richardson Mountains.

The settlement of Aklavik is approximately 80 km north of Fort McPherson and 55 km west of Inuvik, extending about 1.8 km along the bank of the Peel Channel

POPULATION

During the 1920's and 1930's Aklavik was the main centre of activity north of the Arctic Circle and experienced its greatest growth during this period of time. During the 1950's government decision created the new Town of Inuvik to act as the governmental and transportation centre for this area of the Mackenzie Delta. Since people in Aklavik were paid to relocate elsewhere the population decreased slightly during this period. The population in 1958 was 700 and by 1961 was 670. Since 1962 there has been a slow increase in population, partly due to natural increase and partly to the return of families from the new Town of Inuvik. There has been a general trend of native population returning to Aklavik as they became disenchanted and unhappy in the larger, faster moving Town of Inuvik with its urban problems of growth. Present population (Jan. 1979) is 797. Future population and water demand forecasts are listed in Table 1 and 1 (a); also refer to Figure 2.

New development is slated to follow the southwest bank of the Peel Channel. (See Figure 1) 72 new lots have been planned in this area; this should be sufficient for 8 - 10 years.

SOILS

The townsite of Aklavik is about 3.5 m above summer water level and 10 m above sea level which has resulted in occasional flooding of the Hamlet. The townsite is composed of relatively recent alluvial deposit. This material consists of silts and fine sands of considerable thickness. Permafrost is continuous throughout the settlement at a depth of .31 m to .92 m depending upon the location and combines with the alluvial soils to present drainage, building and erosion problems.

TABLE 1: Present and Future: Population & Demand

Year	Population	Per Capita Demand L/day (a)		
		Fully Trucked (b)	Piped/Trucked (c)	Fully Piped (d)
1978	797	35		
1983	891	90	136	454
1988	996	114	149	454
1993	1113	117	153	454
1998	1245	120	156	454
2003	1392	123	160	454
2008	1557	126	167	454

NOTES: (a) from Local Government guidelines
 (b) trucked water delivery and sewage disposal
 (c) piped water services and trucked sewage disposal
 (d) piped water delivery and sewage disposal

TABLE 1 (a): Total Daily Demand

Year	Per Capita Demand L/day		
	Fully Trucked (a)	Piped/Trucked (b)	Fully Piped (b)
1978	34,500		
1983	103,100	121,200	404,500
1988	144,400	148,900	452,200
1993	165,300	169,800	505,300
1998	189,800	194,300	565,200
2003	217,900	222,900	632,000
2008	250,200	260,100	706,900

NOTES: (a) calculated by taking the total weekly consumption and dividing by 5.5 - the number of days per week water is delivered.
 (b) strictly daily demand. Since water is delivery by piped 7 days per week.

CLIMATE

The climate of Aklavik is characterized by long cold winters (late September to end of May) and short cool summers (mid June to end of August). Spring and autumn are very short. Winter temperatures are quite cold, with monthly mean temperatures of below 0°C for eight months, with December to February being extremely cold months. Monthly mean temperatures drop to -25°C to -26°C. The monthly mean temperatures rise to 4°C from the months of June, July and August, however, only in July and August does the mean reach 10°C.

The low level of precipitation of 23 cm per year does not prohibit vegetation due to the slow thawing out period and light evaporation. Precipitation is quite seasonal and usually results from an influx of warm moist southern air. The months with the highest precipitation are July, August, October and November.

VEGETATION

The northern portion of the Mackenzie Delta is north of the tree line of the boreal forest and although Aklavik is within the boreal forest, the areas inland of the tree-lined channel banks are covered by a marshy vegetation or muskeg. The chief species are white spruce on higher ground with willows and alder occupying the low lying areas. The southern portion of the delta has balsam, poplar and some black spruce on high ground, and willow and alder tickets in lowland meadows.

PRESENT WATER SYSTEM

The Hamlet of Aklavik is presently serviced by a winter intake from the Peel Channel and summer intake from Pump Lake. A new water treatment building (7.6 m square) was constructed in 1977. Complaints have been voiced by residents regarding the summer water quality - i.e. foreign debris has been findings its way into the drinking water system (fish, etc.). Two tanks, each with a capacity of 227,000 L are present by the new treatment building. The existing water system is shown on Figure 3. The Council has written and described the problem, in their view. See Appendix III.

During spring and summer months the Peel Channel has a high silt content; however, in the winter the water quality is generally good. Pump Lake becomes turbid in spring months when it is flooded from the river. Results from water analysis from Pump Lake indicate very high iron, at all times of the year, as well as high Manganese, Calcium and Magnesium. High color and turbidity becomes a problem in spring and summer months, from both the Peel Channel and Pump Lake. The water is also some what hard. Complete analysis results are presented in Appendix I.

PRESENT WATER SYSTEM cont'd

Data from the report "Mackenzie River Input to the Beaufort Sea" is also presented in Appendix I. This includes sediment loading and grain size analysis of the Peel Channel.

INSTALLATION OF PACKAGE TREATMENT PLANT

In order to meet water quality standards, and future demand levels, an upgrading of the present temporary arrangement of a dual source must be considered. In addition, the existing facilities (winter/summer intake and distribution system) are nearing the end of their useful life. In order to adequately treat high levels of turbidity, iron and other minerals present at certain times of the year; a package treatment plant would be installed in the new water treatment building by the river. This would be used in conjunction with the 13,600 L storage tank (backwash) and the two exterior 227,000 L tanks (total of 454,000 L exterior storage). A properly sized and operated "Water Boy" type treatment plant would be able to handle river water at all times of the year. (Reference Appendix II, letter from Neptune Micro-floc.) In fact, more problems would be encountered treating the lake water. Thus, a package plant and permanent intake into the river would enable a year round supply source. In terms of high silt content, increased alum treatment is recommended. The new treatment plant building is quite close to the water's edge; hence the intake would be about 200 m in length.

One or both of the 227,000 L storage tanks could act as settlement tanks and reduce the alum required. However, the problem of tube settlers should be investigated; they would no doubt be much more effective. They could also provide emergency storage in case the plant was inoperative as well as community fire protection storage. It is reported that one of the tanks leak. This, combined with their age, may make insulating the tanks inadvisable.

There are several alternatives to the sizing of the package plant itself. Presently there are available several models of Water Boy plants. They are: WB-133 (375 L/min, capacity), WB-82 (225L/min. capacity) and WB-27 (75 L/min. capacity). Normally, approximately 2% of the daily flow is used for filter, however, up to 30% of the flow may be required for backwash in times of high turbidity.

If one WB-133 was installed, this would be adequate to meet 30 year trucked and piped - trucked demands.

INSTALLATION OF PACKAGE TREATMENT PLANT cont'd

If one WB-82 was installed, in conjunction with the existing 18,000 L storage tank, this would be adequate to meet 1985 demands (fully trucked). If one of the 227,000 L tanks were insulated and heated, 30 year demands could be met for trucked and piped/trucked systems. The plant would then be running constantly; running at night to provide water for peak day periods. If, at a future date, a fully piped system was constructed, the only way demand could be met would be by installation of a WB-133 and provision of a 370,000 L storage.

Presently, during periods of high silt content in the river (spring break-up), and in summer months, a temporary intake and supply line from Pump Lake is utilized. However, the quality of water is not acceptable from this source in several categories: excessive hardness, iron, manganese, colour, turbidity, and perhaps most alarming, coliform counts. There have also been reports from users as to organic matter present in the drinking water. Treatment is most certainly recommended.

If Pump Lake is utilized for a supply source, there are several alternatives for improving the quality of this source:

- a) Construction of a dyke across the narrows of the lake. This would prevent the high silt content from the Peel Channel from entering the lake. However, the lake would have to be recharged via pumping or some type of control structure. The lake would be recharged in fall months once water quality has improved. An access road would be required to the dyke site of approximately 440 m in length. Unfortunately, no soils or detailed topographical information exists of the area. It is estimated the dyke would be approximately 2.5 m high by 60 m in length. A timber control structure would regulate the water inflow.

A permanent intake, wet well and summer line to the treatment plant could be considered. Presently, only a fire hose is used, with pumps suspended on a tripod. This would require about 50 m of intake, a pumphouse building, and approximately 510 m of supply line. In addition, about 310 m of new smaller diameter line would be required to run back to the old treatment plant and tie into an existing summer pressure distribution system.

The above alternatives, i.e. the dyke and permanent intake and pumping facilities, were discussed in reference to Pump Lake. These same options could be applied to the lake west of Pump Lake.

A dyke could also be constructed across the narrows of the west lake. This would impound less water than a Pump Lake dyke, however, it may be slightly easier to construct, although again no soils or topographic information exists. It appears the dyke would be about 3 m high by

INSTALLATION OF PACKAGE TREATMENT PLANT cont'd

60 m long. An access road of approximately 460 m in length would be required. Replenishment would be via control structure, flooding the lake in fall months, or pumping. Water quality is unknown, but, since the lake is flooded from the Peel Channel floods, it is expected to be similar to Pump Lake. This lake has the advantage of being further from town, from a contamination standpoint, but also further to run pipelines. Again, a permanent intake, wet well, and pipeline could be constructed at the west lake. An 1160 m supply line to the treatment plant would be required, as well as a 310 m long small diameter line to the summer distribution system.

ESTIMATED COSTS

Alternative A

Installation of one WB-133 package plant and permanent intake.

Purchase of WB-133	\$ 40,000.00
Freight	2,050.00
Installation	25,000.00
Outfall line (see below)	86,200.00
Intake (see below)	<u>102,000.00</u>
	\$255,250.00
Engineering and contingency 25%	<u>63,750.00</u>
TOTAL	\$319,000.00

Alternative B

Installation of one WB-82 package plant, insulation of one tank, and permanent intake.

Freight (WB-82 from Ft. Simpson)	\$ 1,400.00
Installation	20,000.00
Outfall (see below)	86,200.00
Intake (see below)	102,000.00
Tank insulation & heating (or tube settlers)	<u>30,000.00</u>
	\$239,600.00
Engineering and contingencies 25%	<u>60,000.00</u>
TOTAL	\$299,600.00

...../7

Intake detailed costs:

River intake	200m x \$250.00/m	\$ 50,000.00
Wetwell, pumps, piping		50,000.00
Supply line	20 m x \$100.00/m	<u>2,000.00</u>
TOTAL		\$102,000.00

NOTE: Riprap from outfall costs utilized for intake construction also.

Outfall detail costs:

200 m - 200 mm pipe @ \$250/m	\$ 50,000.00
Plant connection and piping	6,200.00
Riprap (1500 m ³ @ 19.50/m ³)	<u>30,000.00</u>
	\$ 86,200.00

Should the treatment plant prove unable to handle high silted spring river water, then the summer lake source should be improved. This will involve the following expenditures:

ALTERNATIVE I Pump Lake Improvements

Dyke construction	150 m ³ x \$15.00/m ³	\$ 2,250.00
Control structure		15,000.00
Road	440 m x \$100.00/m	44,000.00
Intake	50 m x \$250.00/m	12,500.00
Pumphouse building, pumps, etc.		75,000.00
Summer supply line	510 m x \$50.00/m	30,000.00
Summer distribution line	310 m x \$50.00/m	<u>15,500.00</u>
		\$194,850.00
Engineering and contingencies 25%		<u>48,700.00</u>
TOTAL		\$243,550.00

ALTERNATIVE II West Lake Improvements

Dyke	180 m ³ x \$15.00/m ³	\$ 2,700.00
Control structure		15,000.00
Road	460 m x \$100.00/m	46,000.00
Intake	50 m x \$250.00/m	12,500.00
Pumphouse		75,000.00
Summer supply line	1160 m x \$60.00/m	69,600.00
Summer distribution line	310 m x \$50.00/m	<u>15,500.00</u>
		\$236,300.00
Engineering and contingencies 25%		<u>59,075.00</u>
TOTAL		\$295,375.00

DISCUSSION

Thus, it can be seen that in order to utilize either of the two lakes as a supply source, it will require a minimum expenditure of \$243,550.00. This would be in addition to the treatment plant work. The disadvantages of the lakes include poor water quality, and with the possibility of town encroachment, the water quality could deteriorate further.

Since the supplier recommends treatment of river water year round, it is suggested that this approach be pursued.

The recommended alternative is the installation of a package treatment plant and year round intake into the Mackenzie River. With proper plant operation, year round operation should be feasible. However, pre-settling the river water in the spring months would aid in the operation of the plant, thus, tube settlers should be investigated. The condition of the tanks should also be carefully assessed, and, if reasonable life could be expected, then it should be insulated. It is also recommended that water samples be obtained this spring from the river, these analysis would aid in the plant set up and determining optimum chemical dosages. Applications should also be made for water board approval of the plant effluent discharge (backwash waste) outfall line.

The 1978/79 budget of \$10,000.00 with the addition of the 1979/80 budget of \$275,000.00 is not quite sufficient for Alternative B. However, it is within 10%, and it is recommended Alternative B be pursued - the total estimated costs of \$299,600.00.

If design is undertaken immediately; tender documents could be ready by late March. Barge dates for Aklavik are June 1, June 27, July 26 and final sailing August 28 (from Hay River).

Therefore the recommended schedule is:

- mid February - engage consultant
- late March - tender documents complete
- mid April - advertise tender
- late May - contract award
- late June - water boy from Ft. Simpson on barge to Aklavik
- early Sept. - contractor should be able to demobilize equipment via last barge.

SUMMARY OF RECOMMENDATIONS

It is recommended Alternative B be implemented - i.e. installation of the WB-82, from Fort Simpson; installation of intake/outfall and provision of storage. Specifically the project is as follows (for a guide to consultants):

Preliminary Sitework & Engineering

This phase will involve at least one site visit to gather design information as river depth profiles at intake/outfall location; water sampling at spring breakup and water temperature measurement at intake depth. The existing tanks should be evaluated for useful life. Tube settling devices should be investigated and assessed.

Design & Tender Documents

- a) Intake/outfall: An inclined shaft type intake is preferred. All required piping and electrical work. Intake/outfall to be protected from ice damage; perhaps by running them through culverts covered with riprap. 1500 m³ of riprap will be stockpiled during the winter of 1979; for use in this project.
- b) Installation of WB-82: The plant is to be shipped from Fort Simpson; all mechanical and electrical work as required. The existing tanks should be piped so as to use for storage. If feasible, the one tank should be insulated and used for active storage. A hook-up for the summer distribution system is required. Tube settlers, if practical and economic, to be installed.
- c) Services during construction: This phase would include periodic advice from designers during construction, site visits if required, preparation of as-built drawings and O & M manuals.
- d) Resident Supervision: It is doubtful whether a job of this magnitude would warrant a full time resident inspector.


development plan
AKLAVIK N.W.T.

○ areas to be landfilled

FIGURE 1

FUTURE
EXPANSION
AREA


0 100 200 400




— TOTAL DAILY DEMAND: '000 gal/day
— POPULATION

AKANK

FIGURE 2



**SCHEMATIC OF WATER
TREATMENT AT AKLAVIK**



NOTE:
ROTIFLOW UNIT
NOT SHOWN

APPENDIX I
WATER ANALYSIS
PUMP LAKE
PEEL CHANNEL

Constituents In mg/l	Hawkesbury River Peel Channel			Water Supply Lake			
	July 27, 1949	Jan. 15, 1961	Sept. 9, 1958	July 27, 1949	May 27, 1968	June, 1968	Sept. 1968
Acidity as CaCO ₃	7.6 (141.4)	7.7 (196.6)	8.1 (184.0)	7.3 120.0	-	7.2 (210.0)	8.6 96.0
Phosphate in Alk-							
Acidity as CaCO ₃	0	0	0	0	-	0	4.0
Total Alk. as CaCO ₃	105.0	148.0	136.0	120.0	-	184.0	88.0
Iron (Fe) (Total)	0.5	<0.05	0.29	0.3	-	1.14	0.3
Manganese (Mn) (Total)	-	0	-	-	-	0.22	-
Hardness (Units)	30	<5.0	<5.0	15	5	175.0	10.0
Turbidity (Units)	Heavy Silt	<0.1	15.5	Present Colloidal	12	50.0	2.0
Nitrate Nitrogen (N)	0.082	0.18	-	0.041	-	0.16	-
Nitrite Nitrogen (N)	Trace	<0.001	-	0	-	<0.001	-
Ammonia Nitrogen							
Total Nitrogen	Negligible	0.02	-	Negligible	-	0.28	-
Mineral Nitrogen (N)	0.017	0.03	-	0.13	-	0.52	-
Calcium (Ca)	38.5	51.2	53.9	37.2	-	49.8	20.8
Magnesium (Mg)	11.0	16.7	12.0	11.1	-	20.7	10.7
Sulfur (S)	2.5	2.8	-	3.0	-	8.7	-
Potassium (K)							
Bicarbonate as CO ₃	63.0	88.8	81.6	72.0	-	110.4	48.0
Carbonate (CO ₃)	0	0	0	0	-	0	4.8
Sulfate (SO ₄)	39.6	49.4	-	22.3	-	31.6	-
Chloride (Cl)	0.6	5.0	-	1.4	-	8.0	-
Nitrate (NO ₃)	0.35	0.8	-	0.2	-	0.7	-
Fluoride (F)	Negligible	0.17	-	0.05	-	N.D.	-
Silica (SiO ₂)	7.4	9.6	-	2.6	-	7.4	-
Filterable Residue on Filtration at 105°C	192.0	232.4	228.0	190.0	-	330.4	140.0
Alkalinity	8.0	7.7	7.7	7.9	-	7.7	8.3
Hardness Index	-0.4	0	+0.4	-0.6	-	-0.5	+0.3

- None Detected

Analysts: F.E. Artlett and R. Holowaty.

Constituents In mg/l	Hudsonia River Peel Channel			Water Supply Lake			
	July 27, 1949	Jan. 15, 1961	Sept. 9, 1958	July 27, 1949	May 27, 1968	June, 1968	Sept. 1968
Acidity as CaCO ₃	7.6	7.7	8.1	7.3	-	7.2	8.6
Phosphate in Alk-	141.4	196.6	184.0	120.0	-	210.0	96.0
Alkalinity as CaCO ₃	0	0	0	0	-	0	4.0
Total Alk. as CaCO ₃	105.0	148.0	136.0	120.0	-	184.0	88.0
Iron (Fe) (Total)	0.5	<0.05	0.29	0.3	-	1.14	0.3
Iron (Fe) (Total)	-	0	-	-	-	0.22	-
Hardness (Units)	30	<5.0	<5.0	15	5	175.0	10.0
Hardness (Units)	Heavy Silt	<0.1	15.5	Present Colloidal	12	50.0	2.0
Nitrate Nitrogen (N)	0.082	0.18	-	0.041	-	0.16	-
Nitrite Nitrogen (N)	Trace	<0.001	-	0	-	<0.001	-
Ammonia Nitrogen	Negligible	0.02	-	Negligible	-	0.28	-
Ammonia Nitrogen	0.017	0.03	-	0.13	-	0.52	-
Calcium (Ca)	38.5	51.2	53.9	37.2	-	49.8	20.8
Magnesium (Mg)	11.0	16.7	12.0	11.1	-	20.7	10.7
Sodium (Na)	2.5	2.8	-	3.0	-	8.7	-
Potassium (K)	-	-	-	-	-	-	-
Carbonate as CO ₃	63.0	88.8	81.6	72.0	-	110.4	48.0
Bicarbonate (CO ₃)	0	0	0	0	-	0	4.8
Sulfate (SO ₄)	39.6	49.4	-	22.3	-	31.6	-
Chloride (Cl)	0.6	5.0	-	1.4	-	8.0	-
Nitrate (NO ₃)	0.35	0.8	-	0.2	-	0.7	-
Fluoride (F)	Negligible	0.17	-	0.05	-	N.D.	-
Silica (SiO ₂)	7.4	9.6	-	2.6	-	7.4	-
Filterable Residue on Filtering at 105°C	192.0	232.4	228.0	190.0	-	330.4	140.0
Specific Conductivity	8.0	7.7	7.7	7.9	-	7.7	8.3
pH Index	-0.4	0	+0.4	-0.6	-	-0.5	+0.3

- None Detected

Analysts: F.E. Artlett and R. Holowaty.

DEPARTMENT OF NATIONAL HEALTH AND WELFARE
PUBLIC HEALTH ENGINEERING DIVISION

CHEMICAL ANALYSIS OF WATER

Aklavik, H.W.T.

Date Sampled: 1. Feb. 19, 1971.
2. May 10, 1971.

Locating Marks: Pump Lake

Sampled By: T.A. Roy

Analysed By: J.W. Grainger

Date Received In Lab.: 1. Mar. 16, 1971.
2. May 20, 1971.

Constituents, in Milligrams per Liter	Sample No. 1	Sample No. 2	Sample No. 3	Max. Sample Permissible
Calcium (Ca)	7.7	7.3	7.75	6.5-8.3
Magnesium (Mg)	588	900	150	200
Total Hardness as CaCO ₃	Nil	Nil	Nil	200
Total Alkalinity as CaCO ₃	592	934	149	200
Total Hardness (Total)	10.64	6.63	1.4	10
Total Chloride (Cl) (Total)	1.24	3	0.5	0.5
Total Iron (Fe) (Units)	60	35	15	15
Total Nitrogen (N) (Units)	6.4	11.09	1	5
Ammonia Nitrogen (N)	1.12	0.56	0.01	10
Nitrite Nitrogen (N)	0.66	2.6	0.01	10
Nitrate Nitrogen (N)	136.1	211.6	0.01	200
Total Hardness (Ca)	136.1	211.6	0.01	200
Total Hardness (Mg)	60.2	90.2	1	150
Total Hardness (Na) - Calculated	18.5	34.7	1	150
Total Hardness as CO ₃	355.2	560.4	1	150
Total Hardness (CO ₃)	Nil	Nil	Nil	150
Total Hardness (SO ₄)	13	2.6	1	250
Total Hardness (Cl)	16	26	1	250
Total Hardness (F)	0.37	0.34	0.7	12
Total Dissolved Solids - Determined	720.5	1091.5	100	1000

highly turbid

LICENSEE AKIADIK DATE 28-6-77 SAMPLED BY D.A.N.D.
 LICENCE NO. 4571-1-1 LOCATION _____

STATION NUMBER	1	2			
LABORATORY NUMBER	70278	70279			
pH (units)	5.1	8.0			
Sp. Conductance (umho/cm)	27	536			
Dissolved Oxygen					
Turbidity (JTU)	2.0	6100			
Colour	25				
Suspended Solids	2.0	4.0			
TDS, Residue					
Oil & Grease					
Total Coliform (cnt/100 ml)	>2750	>1x10 ⁶			
Faecal Coliform (" ")	<1.0	>1x10 ⁵			
Faecal Strep. (" ")					
BOD ₅					
COD					
Carbon, IC					
Carbon, TOC					
Calcium	31.7	36.3			
Magnesium					
Total Hardness CaCO ₃	115.0	154			
Total Alkalinity CaCO ₃	42.5	228			
Sodium					
Potassium					
Total Cyanide					
Chloride					
Sulphate					
Sulphide					
Ammonia Nitrogen N	0.2				
Nitrate/Nitrite N	<0.01	173			
Total Kjeldahl N N	0.31	22.5			
Phosphorus O-P P					
Phosphorus Total P	0.046	2.13			
Silica Reactive SiO ₂					
Arsenic T					
E					
Cadmium T					
E					
Copper T					
E					
Iron T					
E					
Lead T					
E					
Mercury T					
E					
Nickel T					
E					
Zinc T					
E					

All results are expressed in mg/l except as indicated in brackets ().
 O-P = ortho phosphate; TDS = total dissolved solids and is the filterable residue, dried at 104°C; T = Total; E = Extractable; IC = inorganic carbon; TOC = total organic carbon.

1. *Summit Lake*
2. *Camp outfall upstream from outflow into Red Channel.*

Computed by _____ Date _____

Checked By _____

DEPARTMENT OF THE ENVIRONMENT
INLAND WATERS BRANCH WATER SURVEY OF CANADA

SUMMARY OF SUSPENDED SEDIMENT ANALYSIS RESULTS FOR YEAR 1975

Stream Mackenzie River Peel Channel Location above Alavik

Date	Time	Water Level	Temperature °C	Sample Location	River Depth	Sample Depth	Type of Sample	Sample Number	Volume Sampled (L)	Total Sample Dry Weight (g)	Total Concentration (mg/l)	Total Sample P/g (mg/l)	% Sand (0.075-0.075 mm)	% Silt (0.075-0.075 mm)	% Clay (0.075 mm)	Dissected Sand (mg/l)
June								NA								
17	1640		11.0		37.0		D.I.	100132	855	5052	597	0077	3	57	40	128
23	1400		16.0		38.0		"	100215	625	1950	317	0067	3	55	42	154
July								NA								
17	1950		20.5	275	9.5		D.I.	100115	460	0579	81					193
17			"	274	13.5		"	04	505	0367	92					181
17			"	156	22.6		"	05	647	0606	91					151
17			"	105	41.0		"	06	801	1591	199					173
17	2005		20.5	57	28.9		"	07	632	1210	302					

Computed by _____ Date _____

Checked By _____ Date _____

MACKENZIE RIVER (PFEL CHANNEL) ABOVE AKLAVIK - STATION NO. 10NC003
SUSPENDED SEDIMENT FOR 1974

DAY	MAY				JUN			
	DAILY DISCHARGE (CFS)	MEAN CONCENTRATION (MG/L)	TONS PER DAY	TEMP. (C)	DAILY DISCHARGE (CFS)	MEAN CONCENTRATION (MG/L)	TONS PER DAY	TEMP. (C)
1	03600	325	74300		03600	402	94600	1
2	07200	400	121000		91600	575	151000	3
3	91600	400	151000		95900	665	167000	5
4	104000	665	167000					
5	104000	677	190000					
6	91300	574	152000					
7	91100	479	116000					
8	85400	385	90000					
9	79000	326	68700					
10	71900	269	52200					
11	66500	222	39500	6.1				
12	61500	168	31700					
13	57200	177	27200					
14	53400	164	26500					
15	50600	205	24000					
16	47900	245	31700					
17	45600	300	36500					
18	43400	350	41000					
19	41700	405	45600					
20								
21	40600	457	50100					
22	37600	504	52500					
23	36900	547	57500					
24	36300	574	59400					
25	37900	603	61700					
26	37400	611	63700					
27	37000	607	60600					
28	37100	601	60200					
29	36500	594	59200					
30	36500	589	58000					
31								
TOTAL MEAN	1036700		2169100		73000		73000	

MACKENZIE RIVER (PEEL CHANNEL) ABOVE AKLAVIK - STATION NO. 10MC003
 SUSPENDED SEDIMENT FOR 1974

JUL										AUG										SEP									
DAY	TEMP. (C)	DAILY DISCHARGE (CFS)	MEAN CONCENTRATION (MG/L)	TONS PER DAY	TEMP. (C)	DAILY DISCHARGE (CFS)	MEAN CONCENTRATION (MG/L)	TONS PER DAY	TEMP. (C)	DAILY DISCHARGE (CFS)	MEAN CONCENTRATION (MG/L)	TONS PER DAY	TEMP. (C)	DAILY DISCHARGE (CFS)	MEAN CONCENTRATION (MG/L)	TONS PER DAY	TEMP. (C)	DAILY DISCHARGE (CFS)	MEAN CONCENTRATION (MG/L)	TONS PER DAY									
1	26900	585	585	59700	15.6	39400 A	349 S	37100		33600	161	14600		33000	164	14600		33000	164	14600									
2	26900	584	584	58200		36000 E	246	25200		33900	185	14600		33900	185	14600		33900	185	14600									
3	26900	578	578	57700		34500 E	180	17700		32500	161	11900		32500	161	11900		32500	161	11900									
4	26900	575	575	57100		35500 E	132	12700		32300	137	11900		32300	137	11900		32300	137	11900									
5	26100	570	570	55600		34300 E	104	9630		30800	115	5900		30800	115	5900		30800	115	5900									
6	25400	565	565	54000		34000 E	85	7800		29400	112	8150		29400	112	8150		29400	112	8150									
7	25000	555	555	52700		34200 E	32	7700		29000	106	8010		29000	106	8010		29000	106	8010									
8	24600	554	554	51800	16.1	35300 A	107 S	10200		28000	106	8010		28000	106	8010		28000	106	8010									
9	24200	549	549	51400		37800	179	16300	7.2	27000	99 S	7250		27000	99 S	7250		27000	99 S	7250									
10	23700	545	545	50300		40000	281	30300		25900	91	6300		25900	91	6300		25900	91	6300									
11	23200	540	540	49600		41200	394	43800		24700	83	5540		24700	83	5540		24700	83	5540									
12	23000	536	536	48400		42300 A	510	58200		23800	75	4220		23800	75	4220		23800	75	4220									
13	22400	521	521	47000		41500 E	624	73300		23700	67	4200		23700	67	4200		23700	67	4200									
14	22500	477	477	42100		45500 E	719	16400		22400	60	3010		22400	60	3010		22400	60	3010									
15	22700	367	367	32500	13.3	65500 E	749 S	92000		21600	52	3010		21600	52	3010		21600	52	3010									
16	21500	216	216	12200		46000 E	693	26100		20900	54	2400		20900	54	2400		20900	54	2400									
17	20400	110	110	9030		47000 E	681	26400		20000	37	2000		20000	37	2000		20000	37	2000									
18	20400	71	71	5640		50000 E	759	102000	6.1	19500	33 S	1700		19500	33 S	1700		19500	33 S	1700									
19	20200	63	63	5120		52000 E	858	122000		19100	34	1750		19100	34	1750		19100	34	1750									
20	20700	63	63	5050		54000 E	904	132000		18900	32	1650		18900	32	1650		18900	32	1650									
21	20700	62	62	4970		54000 E	815	119000		19900	32	1650		19900	32	1650		19900	32	1650									
22	20300	61	61	4830		52000 E	707	99300		19900	33	1650		19900	33	1650		19900	33	1650									
23	20000	60	60	4750		50000 E	599	40900		19400	31	1570		19400	31	1570		19400	31	1570									
24	20300	54	54	5170		48500 E	500	65500		18700	35	1570		18700	35	1570		18700	35	1570									
25	20300	110	110	5210		47000 E	413	52400		18100	37	1410		18100	37	1410		18100	37	1410									
26	22700	205	205	12100		45000 E	332	40300		17500	34	1410		17500	34	1410		17500	34	1410									
27	24900	316	316	29700		42500 E	270	31000		17000	32	1300		17000	32	1300		17000	32	1300									
28	27100	425	425	42800		40000 E	232	29100		16800	30	1200		16800	30	1200		16800	30	1200									
29	26500	531	531	55200	10.9	37600 A	193 S	19600		17800	38	1830		17800	38	1830		17800	38	1830									
30	29400	584	584	67100		36400	173	15900		17000	38	1830		17000	38	1830		17000	38	1830									
31	29800	487	487	52100		34800	169	15900		16100	37	1410		16100	37	1410		16100	37	1410									
TOTAL	1047000	1101270	1101270	1101270		1319400	1624030	1624030		706100	163700	163700	TOTAL	706100	163700	163700	TOTAL	706100	163700	163700									
MEAN	33600	50550	50550	50550		42600	52400	52400		23500	5450	5450	MEAN	23500	5450	5450	MEAN	23500	5450	5450									

APPENDIX II


WATER BOY INFORMATION

**neptune
/microfloc**

3526 LAKESHORE BLVD. W., TORONTO, ONTARIO, CANADA M8W 1N7

November 29, 1978

Government of the Northwest Territories
Project Management, Eng. Division
Department of Public Works
Yellowknife, N.W.T.
X1A 2L9



Attention: Mr. R. Yaworsky
Project Officer

Dear Sir:

RE: Aklavik Water Analysis

We have reviewed the water analysis forwarded to us with your letter of October 27, 1978, and would advise as follows.

For the Mackenzie River water we would recommend the use of a Microfloc Water Boy rated at normal capacity. Although we have no direct experience with the treatment of Mackenzie River water, after reviewing the water analysis submitted, we are sure that it will offer no resistance to conventional chemical treatment and mixed media filtration.

For the water supply lake for which the water analysis was submitted, we would recommend the use of a Microfloc SWB unit. This unit is recommended due to the high colour referenced in the analysis. The SWB offers greater retention time and higher solids handling capabilities which, we feel, is required for this water. The SWB is available in packaged plant sizes ranging from nominal flow handling capabilities of 25,000 - 250,000 U.S. gallons per day.

I am enclosing some information in reference to the Recla-Mate SWB unit and trust you will find this of some value. We would be pleased to review appropriate equipment selection for this project at your earliest convenience. Our representative in your area is Mr. Ray McManus of B & D Engineering Sales, 70th Avenue S.E., Calgary, telephone 259-5358 (Area Code 403). Mr. McManus may be contacted should you require additional information, or, you may contact me directly.

I trust this information will help you in your review for equipment selection on this project.

Yours truly,

*1-2% daily flow backwash.
- backwash once/day.*

NEPTUNE MICROFLOC LIMITED

Treat silt with Alum.

George Reddom
Applications Specialist

GR/ir encls.

WATER BOY WB-82

P.O. BOX 612-1565 AIRPORT ROAD
CORVALLIS, OREGON 97330
Telephone (503) 752-5501

General Data

Nominal Flow: 60 gpm. Maximum Flow: 70 gpm.

Inlet Pressure Required @ Shutoff: 10 psig.

Effluent Pressure Available @ Rated Flow: 10 ft. of water (from base of unit).

Overall Shipping Dimensions:

Length: 8 ft. 9 in. Width: 7 ft. 10 in. Height: 6 ft. 10 in.

Weights:

Shipping weight: 8,000 lbs. Operating weight: 24,000 lbs.

Equipment Included with Basic Unit (See Drawing M-292)

Influent Rate Set Valve: 2 in.

Rapid Mix Chamber: 24 ft³ volume.

Flocculator: 80 ft³ volume. Drive: 1/4 hp, 12 rpm.

Tube Settler: 81 ft³ volume. Overflow Rate: 300 gpd/ft².

Filter Area: 12 ft². Media Type: MF-162. Underdrain: Header and Lateral.

Pumps: Effluent - 1-1/2 hp, 60 gpm.

Backwash - 5 hp, 216 gpm; flooded suction required.

Controls:

Plant flow rate is set manually by an adjustable influent float valve. Another float valve on the effluent pump discharge maintains constant filter level to match incoming flow. A low filter level protection switch is provided for effluent pump protection. The control panel provides automatic backwash initiated by preset filter headloss or by manual pushbutton. Return to service is automatic. Load center and motor starters for pumps also provided and mounted on unit.

Finish: Interior - 6 mils dry film thickness vinyl. Color: Aqua.

Exterior - 4.5 mils dry film thickness vinyl. Color: Aqua.

Chemical Feed:

Alum - 50 gal. tank, 60 gpd pump, max. feed 100 ppm.

Hypochlorite - 50 gal. tank, 60 gpd pump, max. feed 4 ppm.

Polyelectrolyte - 50 gal. tank, 24 gpd pump, max. feed 1 ppm, 1/3 hp mixer.

Soda Ash (optional) - 50 gal. tank, 60 gpd pump, max. feed 35 ppm.

Installation Data

WATER BOY is designed for indoor installation.

Base Pad Design: 600 lbs. per ft².

Electrical Supply (to load center on unit): 120/240 V, 3 phase, 30 amp circuit.

Pipe Connections:

Inlet - 2 in.

Effluent - 2 in.

Backwash - 4 in.

Waste Line for Backwash Flow - 8 in.

Minimum Backwash Water Storage Required: 2,400 gallons.


Overhead Clearance Required: 4 ft. 0 in.

KS 5.38-3
Rev. 7-72

216 gpm

8700

WANTUNA MICROFILMS, INC. 1965 AIRPORT RD. CORVALLIS, OREGON 97330 503-752-5501



- LEGEND**
- NORMAL FLOW
 - > REVERSE FLOW
 - - - - - RETURNED FLOW
 - RETURN
 - ⊗ EXHAUSTION FROM MOTOR
 - ⊙ EXHAUSTION FROM FLOWMETER
 - ⊕ DRIVE MOTOR
 - ⊖ ELECTRICALLY OPERATED VALVE
 - ⊗ AIRWALL ANTI SIFT VALVE
 - ⊕ TANGENTIAL FLOW
 - ⊕ ANTI SWIRL DISINTEGRATOR
 - ⊕ FLOW GATE
 - ⊕ AIRLIFT LOCKING
 - ⊕ AIRLIFT SWITCH
 - ⊕ LIFT SWITCH

NOTES

DATE: 11/15/54

BY: [Signature]

PROJECT: WATER TREATMENT PLANT


SCALE: AS SHOWN

REVISIONS:

NO.	DATE	DESCRIPTION
1	11/15/54	AS SHOWN

WATER BOY
FLOW DIAGRAM

DCM





- NOTES**
1. REFER TO SEPARATE NMI EQUIPMENT LIST FOR DETAILED DESCRIPTION OF ITEMS FURNISHED BY REPUTABLE MANUFACTURER.
 2. SHIPPING WEIGHT OF WB-82 ASSEMBLY IS APPROX 8,000 LBS.
 3. RECOMMENDED OVERHEAD CLEARANCE FOR SERVICE AND MAINTENANCE IS 4'-0" ABOVE PLANT.
 4. RECOMMENDED CLEARANCE FOR FRONT PANEL AND LEFT SIDE IS 4'-0" FOR ACCESS CLEARANCE FOR FRONT SIDE IS 1'-6" MINIMUM.
 5. SEE DWG ELECTRICAL CONTROL ELECTRICAL DWG FOR WIRING DIAGRAM AND DWG ELECTRICAL INTERCONNECTION DIAGRAM.
 6. POWER SUPPLY TO BE 120/240VOLT, 4 WIRE DC 1PH, 50, 60 HZ, 50 AMP.
 7. PLANT CONTROLLER IS PROVIDED WITH A CONTACT FOR AUTOMATICALLY START AND STOP A 5-HP MOTOR. THIS MOTOR IS SUPPLY ISOLATION CONTACT. GRAVITY SAVE CONTACT WILL ENERGIZE CONTACT. A CURRENT LIMITER IS PROVIDED TO PROTECT THE CONTACTS FROM EXCESSIVE CURRENT. THIS VALUE CAN BE ADJUSTED BY THE USER. THIS VALUE CAN BE ADJUSTED BY THE USER. THIS VALUE CAN BE ADJUSTED BY THE USER. THIS VALUE CAN BE ADJUSTED BY THE USER.
 8. OPERATOR IN PLANT CONTROLLER IS PROVIDED TO OPERATE WATER STOP VALVE. SWITCH LOCATED IN THE FINISHED WATER STORAGE TANK. CONTACTS SHOULD BE CLOSED ON LOW LEVEL AND OPEN ON HIGH LEVEL. THE STOP VALVE SHOULD BE AT LEAST 3'-0" FROM THE STORAGE TANK. THESE NOTES APPLY TO ALL WATER STOP VALVES.
 9. FINISHED WATER STORAGE TANK SHOULD BE PROVIDED WITH A LEVEL SWITCH FOR BACKWASH. THESE CONTACTS SHOULD OPEN WHEN WATER LEVEL IN LOWER TANK IS VERTICAL POSITION. THESE CONTACTS SHOULD BE PROVIDED WITH A 1/2" NPT CONNECTION. THESE CONTACTS SHOULD BE PROVIDED WITH A 1/2" NPT CONNECTION.
 10. A SHUTTER VALVE IS RECOMMENDED IN THE END TANK SECTION LINE AT THE STORAGE TANK. THESE CONTACTS SHOULD BE PROVIDED WITH A 1/2" NPT CONNECTION. THESE CONTACTS SHOULD BE PROVIDED WITH A 1/2" NPT CONNECTION.
 11. A MINIMUM WATER PRESSURE REQUIRED AT WATER BOY INFLUENT CONNECTION IS 10 PSIG @ 60 GPM.
 12. INFLUENT FLOAT VALVE (V-1) IS PROVIDED TO SET PLANT FLOW RATE. THESE CONTACTS SHOULD BE PROVIDED WITH A 1/2" NPT CONNECTION. THESE CONTACTS SHOULD BE PROVIDED WITH A 1/2" NPT CONNECTION.
 13. WATER LINE AND NOSE ARE RECOMMENDED FOR CHEMICAL MIXING EFFLUENT FROM NOSE BIB ON WATER BOY MAY BE USED.
 14. PARTS LIST CONTAINS MISCELLANEOUS MOUNTING HARDWARE, SPARES AND PLANT OPERATING AIDS.
 15. LOCATION DIMENSIONS FOR INFLUENT EFFLUENT AND BACKWASH CONNECTIONS ARE APPROX REF ONLY. ALLOW FOR MANUFACTURING TOLERANCES.
 16. ITEMS TO BE ASSEMBLED AT JOB SITE BY CUSTOMER. NMI WILL SUPPLY WRITTEN INSTRUCTIONS.

NEPTUNE
Machinery

water boy

Self-contained Water Treatment Plants for
Small Communities, Industries, Parks & Recreational Areas



This 60 GPM Water Boy 82 provides water for an oil company campsite in Alaska. Ten, 20, and 100 GPM units are also available.

Automatic Operation

Advanced Microfloc Technology

Factory Assembly

Easy Installation

Compact Design

WATER BOY is a compact, complete factory-built water treatment plant. The complete water treatment process—coagulation, flocculation, clarification, and filtration—has been integrated into one small steel package designed to permit either permanent or portable installation. WATER BOY requires a minimum of operation skill and attention, yet provides optimum trouble-free service.

WATER BOY is applied on surface supplies, for removal of turbidity, color, and associated suspended matter, and on groundwaters for removal of iron and manganese. The raw water source is always a prime consideration. Raw water temperature and the amounts of suspended matter, color, etc., to be removed are important. At design flow, the WATER BOY will handle 400 units of turbidity at temperatures of 50 degrees or more. Higher applied turbidities and/or lower temperatures suggest derating the plant in proportion to the amount of turbidity. Similarly, favorable raw water conditions and temperatures would allow the operation of these package units at maximum hydraulic capacity.


WATER BOY generally will use alum (aluminum sulfate) for coagulation, a polymer as a coagulant aid, and chlorine for disinfection. In some cases, pH correction may be re-

quired. This can be done by adding soda ash or lime. For taste and odor problems, WATER BOY can utilize either powdered activated carbon or a strong oxidant such as potassium permanganate. For iron and manganese removal, chlorine and/or potassium permanganate and a polymer coagulation aid would be suggested.

Generally, highest quality effluent must be maintained for both industrial and municipal services. Usually, this means effluent turbidity of less than 0.5 JTU, and often 0.1-0.2 JTU. This quality is the norm—not the exception—for the WATER BOY.

Here's how WATER BOY works. The required chemicals are introduced as raw water enters the plant. The chemically dosed water then enters the flash mix chamber. Next, the treated water flows over a calibrated weir to a mechanical flocculator, and on to the unique Microfloc tube clarifier.

FLOW DIAGRAM




BULLETIN NO. KL 4340

water boy

Filtered water enters the mixed-media filter chamber and passes through the filter bed to the underdrain system where it's pumped to the combination clearwell and backwash tank.

Filter backwash is automatic, initiated on headloss. Positive sludge removal from the tube clarifier is integrated in the backwash, and final backwash water refills the settling chamber, cutting plant downtime and wasted water. All pumps, motors, and controls are mounted integrally. Only load center electrical connections and influent, effluent, backwash and waste pipelines are needed to place the unit in service.



TYPICAL PLANT SCHEMATIC

TYPICAL INSTALLATIONS

WATER BOY is utilized to provide water for small communities of from 50 to 2000, and serve the domestic water needs of parks and resorts, schools, and various industries. Additional uses are for construction water, tertiary sewage treatment, and water research.

COMMUNITIES

LAKESIDE UTILITIES, OHIO. Two 20 GPM WATER BOYS provide water for a housing development in northern Ohio. A lake provides the raw water source.

ELK CITY, IDAHO. A 100 GPM unit with turbidity monitoring option. The plant provides water for the community of Elk City, Idaho. A river supply is treated.

INDUSTRIES

PULP MILL, ALABAMA. A water supply for pulp mill personnel is provided by a 100 WATER BOY. The water source is a river.




AIR FORCE, THAILAND. SIX 100 GPM WATER BOY units purchased for an Air Force base in Thailand. The units were transported by air to a remote installation.

POWER PLANT, PENNSYLVANIA. The water supply for power plant personnel is provided by a 100 GPM WATER BOY. Raw water source is a river high in manganese as well as other contaminants.

PARKS

MEMALOOSE STATE PARK, OREGON. A campground operated by the State of Oregon located on the Columbia River utilizes a 20 GPM WATER BOY.

DALE HOLLOW RESERVOIR, TENNESSEE. This Corps of Engineers project uses WATER BOYS for serving the recreation areas.



Neptune Microfloc, Inc.
P.O. Box 612
Corvallis, Oregon 97331
Telephone: (503) 752-5151

A subsidiary of
Neptune International

**B & D ENGINEERING
SALES**
INDUSTRIAL EQUIPMENT

610A - 70th AVENUE S.E.
CALGARY, ALBERTA
CANADA T2H 2J6

Tel. (403) 259-5358 Telex 038-26596


REGIONAL OFFICES LOCATED IN: ST. PETERSBURG, FLORIDA ■ BELLE MEAD, NEW JERSEY ■ DESPLAINES, ILLINOIS ■ DALLAS, TEXAS
IN CANADA, NEPTUNE METERS LIMITED, TORONTO ■ IN JAPAN, NICHOLS FAR EAST LIMITED, TOKYO

Copyright 1975 by Neptune Microfloc, Inc.


Neptune Microfloc

modular aquarius

Water Treatment Plants for Communities and Industry



- Complete Treatment
- Automatic Operation
- Compact Design
- Easy Installation
- Low Costs




AQ 300 treats 2 MGD.

Neptune Microfloc's Modular Aquarius is a unique water treatment plant for communities of 1,000 to 50,000 people and for industry. Modular Aquarius provides complete water treatment — flocculation, settling and filtration — in a compact, economical design which absolutely minimizes capital and operating costs. Five standard models in steel construction are offered: 200, 350, 560, 700 and 1000 gpm. Designs in concrete are available for capacities of 2 to 5 MGD. The advantages offered by Modular Aquarius have made it the choice of consulting engineers, communities and industry in over 100 installations ranging from the United States to South America, Canada, the Caribbean and Australia.


Modular Aquarius offers several unique and important advantages over conventional equipment. Most importantly, Modular Aquarius includes complete water treatment capability. Modular Aquarius provides full mechanical flocculation, tube settling, and Mixed Media filtration. Complete treatment is imperative in the smaller applications where full time, well trained operators are seldom available. Modular Aquarius also offers simple, automatic operation. Constant rate operation based on water level in the filter chamber, automatic sludge removal and automatic backwash initiated on high headloss make the operator's task less complicated, leaving more time for running chemical tests and monitoring treated water quality. A fail-safe turbidity monitoring package which shuts the plant down on high finished water turbidity is also available.

A typical flow schematic for a Modular Aquarius plant, either in concrete or steel, is illustrated. The raw water is either pumped or flows by gravity to the treatment system. Influent flow is set at a fixed, but adjustable, rate with the flow started or stopped by clearwell level. Coagulating and sterilizing chemicals are added upstream of the influent flow control system. The chemically treated water then passes to a mechanical flocculator designed to rapidly form a highly settleable floc. The flocculated water flows

FLOW DIAGRAM



modular aquarius



TYPICAL PLANT LAYOUT

to sedimentation chambers equipped with Neptune Micro-floc's unique settling tubes. The overflow rate based on the surface area of the settling tubes is less than 100 gpd per square foot. The tube settlers remove and store sediment for later wasting from the system.

The clarified water passes over a submerged weir to the Mixed Media filter chamber. The Mixed-Media filter is composed of three materials, each of different size and density. The water passes through the Mixed-Media filter, collects in the pipe lateral underdrain system, and is passed to the clearwell. Backwash of a settler/filter unit is initiated by a pressure switch on the effluent line or by a manual initiation switch on the control panel. The settler/filter is operated as a unit. Each time the filter backwashes, the tube settling section dumps to waste, providing positive sludge removal. The free-falling water surface scours the settling tubes clean.

Modular Aquarius features a compact modular design which lowers capital cost and facilitates future expansion. A complete Modular Aquarius plant fits into the space required for conventional clarification equipment alone, saving 1/3 to 1/2 of the total plant space required for other systems. Low profile minimizes building height. Installation costs are kept low with easily handled, factory assembled modules shipped directly to the jobsite. Expansion is easily accommodated by adding more modules as additional capacity is required.


Modular Aquarius can be applied to either surface supplies or ground water for removal of turbidity, color, iron and manganese, and for partial softening. Generally, alum, polymer (as a coagulant aid), and chlorine are used, with powdered activated carbon and potassium permanganate being applied for taste and odor control.

COMPLETE DESIGN PACKAGE

A pre-engineered design package including drawings and specifications is available to consulting engineers. The package covers the steel Modular Aquarius plants in a no-frills, yet complete, steel building with all essential internal equipment and facilities. Layout, mechanical and electrical drawings, and recommended specifications are included in the design package.

SOME TYPICAL INSTALLATIONS


Mulgrave, Nova Scotia - 1972AQ-70
Shelburne, Nova Scotia - 1972AQ-70
Inco (Ontario) - 1972AQ-40
Falconbridge Mines (Ontario) - 1974AQ-70
Lumsden, Newfoundland - 1973AQ-40
Farmer's Dairy (N.S.) - 1975AQ-40
Mitchell's Bay, Ontario - 1976AQ-40
Shubenacadie, Nova Scotia - 1976AQ-40
Lac Du Bonnet, Manitoba - 1976AQ-50
Enfield, Nova Scotia - 1976AQ-40
Aylmer, Quebec - 1969Concrete
Windsor Mills, Quebec - 1971Concrete
Labatts (Quebec) - 1974Concrete
St. Georges, Quebec - 1975Concrete
Ste. Marie, Quebec - 1975Concrete



neptune B & D ENGINEERING
SALES

610A - 70th AVENUE S.E.
CALGARY, ALBERTA
CANADA T2H 2J6

INDUSTRIAL EQUIPMENT Tel. (403) 259-5358 Telex 038-265



MICROFLOC DIVISION
NEPTUNE METERS LTD.
875 GILLIAN STREET
MISSISSAUGA, ONTARIO L5C 2V9

VANCOUVER, B.C.
CALGARY, ALTA.
WINNIPEG, MAN.
MONTREAL, QUE.
DARTMOUTH, N.S.

TI 0*
E: 703



4161 259-4211

161 275-9826

recla-mate SWB

Neptune
Microfloc

Tertiary Treatment for Small Communities,
Industry, and Parks and Recreational Areas



This Recla-Mate SWB-50 is currently in service in a resort area in Pennsylvania. It is used to polish effluent from an extended aeration secondary plant, and treat an average daily flow of 30,000 gpd to a tertiary level.

Automatic Operation

Efficient Performance

Advanced Microfloc Technology

Compact Layout


Easy Installation

Neptune Microfloc's Recla-Mate SWB provides a solid answer for those wastewater treatment plant operators today who face unreliable plant processes and rising state and regional discharge standards. Recla-Mate SWB is a compact tertiary treatment system specifically designed to fill the gap—to supplement new or existing secondary treatment facilities and provide an economic way to gain consistent performance and upgrade effluent quality. The SWB can treat a wide range of domestic and industrial effluents— aerated lagoon, activated sludge, trickling filter—to consistent tertiary levels. Chemical coagulation, in combination with mechanical flocculation, tube clarification and Mixed Media filtration, form the basic SWB process. Lime, alum or other coagulants can be used to achieve high levels of phosphate reduction and removal of BOD and suspended solids at reasonable cost. With proper chemical dosage, the SWB can treat secondary effluents with less than 40 mg/l BOD and 100 mg/l suspended solids to final BOD and suspended solids levels of less than 5 mg/l and turbidity to less than 1.0 JTU. In special cases, where high concentrations of soluble organic contaminants must be removed, powdered carbon can be injected ahead of the filter chamber to improve BOD removal.

Recla-Mate SWB can be operated without chemicals if improved reduction of solids only is required and phosphate removal is not necessary. The efficiency of simple settling and filtration without chemicals, of course, will vary with the degree of biological flocculation in the secondary treatment process. When solids in the secondary effluent are not filterable due to excess carry-over or biological upset, chemical treatment can be initiated to maintain a continuously high effluent quality. The amount of chemical treatment can be adjusted to meet the required effluent standard.


Simplicity of operation, low maintenance requirements, and compact size are features of Recla-Mate SWB, as is the fact that its physical-chemical process allows intermittent operation with no sacrifice in efficiency. All plant functions are automatic except for setting the chemical feed rates.

FLOW DIAGRAM



recla-mate SWB

Installation is easy, with connection of inlet, effluent, drain and backwash piping and power hook-up the only requirements. The SWB process operates as follows: Secondary effluent enters the SWB at a constant flow rate, receiving chemical treatment before flowing into the two-cell flocculator. The flocculated wastewater is next settled in the tube settler and filtered through the Mixed Media filter. Filtered effluent is then pumped to the backwash storage/chlorine contact tank from which the final effluent is discharged. The SWB backwashes automatically on headloss across the filter. The tube settler chamber is drained, automatically removing settled sludge, and flow through the filter is reversed. Solids from the tube settler and the filter are drained to a waste storage tank. The Recla-Mate SWB is available in factory-assembled models in capacities ranging from 2,000 to 75,000 gpd and in modular designs from 100,000 to 500,000 gpd. The SWB can be skid-mounted if required.




Typical Plant Layout
150,000 GPD Recla-Mate SWB

TYPICAL PLANT LAYOUT

TYPICAL INSTALLATIONS

- MILL VALLEY RADAR STATION, CALIFORNIA** TWO SWB-50's
Twin plants treat domestic secondary effluent at this California Air Force Station. SWB effluent is sprayed on adjacent land.
- LAKE MEAD FISH HATCHERY, NEVADA** SWB-250
Modular SWB treats hatchery rearing pond effluent generated when the ponds are cleaned. System features skid mounted pumps, valves and controls.
- ANDOVER MALL, MARYLAND** SWB-250
Domestic wastewater from a suburban Washington, D.C. shopping center is treated by extended aeration followed by S.B.
- RICHFIELD SPRINGS, NEW YORK** TWO SWB-150's
SWB treats the effluent from an aerated lagoon. System consistently meets effluent requirements of 5 mg/l BOD and suspended solids and 5 mg/l phosphate.
- MANSEMOND COUNTY, VIRGINIA** TWO SWB-250's
SWB treats 500,000 gpd of secondary effluent from a contact stabilization process.




SWB PERFORMANCE

Quality Parameter	Raw Waste-water Influent	Activated Sludge-Plant Effluent	Recla-Mate-SWB Effluent
COD (Chemical Oxygen Demand) mg/l	200-500	20-60	14-20
BOD (Biological Oxygen Demand) mg/l	250-300	20-40	1-4
Suspended Solids, mg/l	225	60-80	1-4
Phosphorus, mg/l as P	10-15	5.7	0.1-1.0
Turbidity, JTU	100	20-50	0.1-1.0
Color, units	High	High	10-30



Neptune Microfloc, Inc.
P.O. Box 612
Corvallis, Oregon 97330
Telephone: (503) 752-5501
A subsidiary of
Neptune International Corp.

REGIONAL OFFICES LOCATED IN: ST. PETERSBURG, FLORIDA ■ BELLE MEAD, NEW JERSEY ■ DESPLAINES, ILLINOIS ■ DALLAS, TEXAS
IN CANADA, NEPTUNE METERS LIMITED, TORONTO ■ IN JAPAN, NICHOLS FAR EAST LIMITED, TOKYO



FEATURES

		25	50	75	150	250		
NOMINAL FLOW	GPD	25,000	50,000	75,000	150,000	250,000		
	LENGTH	6 ft. 10 in.	9 ft. 6 in.	13 ft. 4 in.	19 ft. 6 in.	31 ft. 4 in.		
	WIDTH	5 ft. 9 in.	8 feet	7 ft. 9 in.	10 feet	10 feet		
SHIPPING DIMENSIONS	HEIGHT	6 ft. 9 in.	6 ft. 10 in.	6 ft. 10 in.	9 feet	9 feet		
	SHIPPING	6,200 lbs.	8,500 lbs.	10,500 lbs.	13,000 lbs.	20,000 lbs.		
	OPERATING	15,000 lbs.	28,500 lbs.	39,000 lbs.	100,000 lbs.	165,000 lbs.		
WEIGHTS	OPERATING	15,000 lbs.	28,500 lbs.	39,000 lbs.	100,000 lbs.	165,000 lbs.		
	OPERATING	15,000 lbs.	28,500 lbs.	39,000 lbs.	100,000 lbs.	165,000 lbs.		
BASE PAD DESIGN	POUNDS/FT. ²	600	600	600	800	800		
BACKWASH VOL.	GALLONS	900	2100	2750	6000	9000		
OVERHD. CLEAR.	FEET	4	4	4	4	4		
	FEET	4	4	4	4	4		
PIPE CONNECTIONS	INLET	1½ inches	2 inches	2½ inches	3 inches	4 inches		
	EFFLUENT	1½ inches	2 inches	2½ inches	3 inches	4 inches		
	BACKWASH	2 inches	4 inches	4 inches	6 inches	8 inches		
	WASTE	3 inches	4 inches	6 inches	6 inches	8 inches		
	OVERFLOW	—	—	—	6 inches	8 inches		
PROCESS COMPONENTS	FLOC. VOL. FT. ³	46	115	125	317	584		
	TUBE SETTLER OVERFLOW	200 GPD./ft. ²	200 GPD./ft. ²	200 GPD./ft. ²	200 GPD./ft. ²	200 GPD./ft. ²		
	FILTER MEDIA AREA	4 ft. ²	9 ft. ²	12 ft. ²	31.5 ft. ²	50 ft. ²		
	PUMPS	EFFLUENT	½ HP, 20 GPM	¾ HP, 40 GPM	1 HP, 60 GPM	3 HP, 125 GPM	5 HP, 220 GPM	
		BACKWASH	1 HP, 76 GPM	3 HP, 175 GPM	5 HP, 230 GPM	10 HP, 630 GPM	15 HP, 850 GPM	
		SURFACE WASH	—	—	—	1 HP, 60 GPM	3 HP, 55 GPM	
	CHEMICAL FEED	CONTROLS		Automatic	Automatic	Automatic	Automatic	
		ALUM	TANK	50 Gallon	50 Gallon	100 Gallon	200 Gallon	400 Gallon
			PUMP	38.5 GPD	120 GPD	120 GPD	22 GPH	22 GPH
			MIXER	½ HP, 115V, 1 Ø	½ HP, 115V, 1 Ø	¼ HP, 115V, 1 Ø	¼ HP, 115V, 1 Ø	½ HP, 115V, 1 Ø
POLYELECTROLYTE		TANK	30 Gallon	50 Gallon	100 Gallon	100 Gallon	200 Gallon	
		PUMP	24 GPD	60 GPD	120 GPD	22 GPH	22 GPH	
		MIXER	½ HP, 115V, 1 Ø	½ HP, 115V, 1 Ø	¼ HP, 115V, 1 Ø	¼ HP, 115V, 1 Ø	½ HP, 115V, 1 Ø	
SODA ASH		TANK	30 Gallon	50 Gallon	100 Gallon	200 Gallon	400 Gallon	
		PUMP	24 GPD	120 GPD	120 GPD	22 GPH	22 GPH	
		MIXER	—	—	—	½ HP, 115V, 1 Ø	½ HP, 115V, 1 Ø	
ELECTRICAL	POWER SUPPLY	120/240V, 60 Hz, 1 Ø 40 Amp	230/460V, 60 Hz, 3 Ø	230/460V, 60 Hz, 3 Ø	230/460V, 60 Hz, 3 Ø	230/460V, 60 Hz, 3 Ø		
	PUMPS	115/230V, 60 Hz, 1 Ø	230/460V, 60 Hz, 3 Ø	230/460V, 60 Hz, 3 Ø	3 CFM @ 80 PSI	3 CFM @ 60 PSI		
IMBRESSED AIR								
FINISH	INTERIOR				6 MIL VIN-3 VINYL	3 MIL VIN-3 VINYL		
	EXTERIOR				3 MIL VIN-3 VINYL			

BULLETIN No. KB 5440

SPECIFICATIONS

GENERAL
 This section of the specification, the contractor shall furnish and install
 -built steel tertiary treatment plant, _____ gpd in capacity similar
 equal to the Recla-Mate model SWB-150, manufactured by Neptune
 Inc., Incorporated, 1905 Airport Road, Corvallis, Oregon.
 Treatment plant shall include chemical treatment, flocculation, settling,
 process pumps, automatic process valves, and controls for automatic
 and backwash. The equipment and materials shall be furnished by a
 supplier, and that supplier's experience must include no less than five
 scale plants utilizing the concepts described herein in operation for 1 year
 more. Suppliers other than the above-named company wishing to quote on
 materials and equipment in this section shall submit suitable evidence of experi-
 ence and results with the above concepts to the engineer and obtain his written
 approval to quote at least 10 days prior to bid opening. The contractor shall pay
 royalty or license fees for use of patented devices or systems and shall pro-
 tect the owner from patent infringement litigation thereon.

PLANT AUTOMATION
 The treatment plant shall be simple to operate and maintain. All functions of
 a plant shall be automated with the exception of establishing flow rate, mixing
 chemicals, and adjusting chemical feed rates.

PLANT CONSTRUCTION
 The major components shall be of the size and shape as shown on the plans,
 combined in a single tank and fabricated of steel plates suitably braced and sup-
 ported. Pipe fittings necessary for connection to external pipe work shall be
 incorporated on plant tankage. The arrangement of the major components,
 utility devices, and equipment shall provide ready access for maintenance.

PAINTING
 Surface preparation and painting shall be performed at the manufacturer's plant
 strict accordance with the paint manufacturer's instructions. Inside surfaces
 shall be provided with both prime and finish coats. A minimum of four coats of
 paint shall be provided on inside surfaces. The outside surfaces shall include
 the prime coat, ready for finish painting in the field. The outside surface shall
 receive one finish coat of paint, compatible with the prime coat used by the
 paint manufacturer, which shall be applied in the field by the contractor in ac-
 cordance with the treatment plant manufacturer's instructions.

Mechanical Flocculator
 The flocculator shall be a two-chamber unit properly baffled to maximize vol-
 umetric efficiency. The flocculator drive shall provide for variable speed opera-
 tion to promote optimum flocculation under variable treatment conditions. Speed
 shall be variable over a 3:1 range, and maximum paddle tip velocities shall not
 exceed 2 feet per second. Mechanical equipment furnished for the flocculator
 impartment for installation by contractor shall include flocculator blades and
 shaft, bearings, drive mechanism, and drive motor.

Settling Chamber
 The settling system provided shall have an overflow design rate of less than
 0.5 gpd per square foot of available settling area. Automatic sludge wasting from
 the settling system shall also be included.

Filter
 The filter area shall be _____ square feet. A pipe lateral underdrain
 system shall provide uniform distribution of the backwash water. This system
 shall be provided for installation by the contractor. A filter surface wash system
 shall also be provided.

Filter Media
 The media shall be of the mixed-media separation bed type composed of
 three materials, each of a different specific gravity and providing a uni-
 form distribution from coarse to fine in the direction of flow with particle
 size ranging from 1.2 mm to 0.25 mm.

Filter Bed
 The filter bed shall be type MF 185, 30 inches in depth. Sufficient media sup-
 port gravel designed for the underdrain system shall be provided. The materials
 shall be furnished by the treatment plant manufacturer and shall be shipped in
 bags for installation by the contractor. Both media and gravel shall be installed
 under the technical direction of the treatment plant manufacturer's representative.

PLANT PROCESS PUMPS
 The treatment plant manufacturer shall furnish one effluent pump, one back-
 wash pump, and one surface wash pump. The effluent pump shall be rated at

_____ gpm, _____ hp; the backwash pump shall be rated at _____
 gpm, _____ hp; and the surface wash pump shall be rated at _____ gpm,
 _____ hp. Pumps to be installed by contractor for SWB-150 and SWB-250,
 factory installed on smaller units.

PLANT PROCESS VALVES
 The treatment plant manufacturer shall provide the process control valves
 shown on the plans. Automatic valves shall be provided for filter effluent rate
 control, backwash waste, and surface wash.

PLANT CONTROL
 The treatment plant supplier shall furnish a control panel containing all neces-
 sary timers, solenoids, contact switches, and internal wiring completely as-
 sembled and mounted in a NEMA 12 enclosure. The control panel shall provide
 for automatically starting and stopping the plant influent pump and chemical
 feeders, based on water level in the collection tank, or by manual override. The
 contractor shall mount the control panel on the Recla-Mate unit and provide all
 electrical wiring and connections external to the panel.

The control system shall provide means for automatically initiating backwash
 of the filter by a preset filter headloss sensor. Override of the automatic back-
 wash initiation shall be provided to allow manual backwash of the filter by push-
 button. The system shall provide for automatically draining the settling system
 contents to the backwash waste storage tank and control of the sludge and
 decant pumps after a timed interval.

For the SWB-150 and SWB-250, the plant manufacturer shall furnish for in-
 stallation by the contractor control devices and equipment as follows: one back-
 wash initiate switch with indicating gauge; one liquid level switch for effluent
 pump protection; one pneumatic liquid level controller to control the filter efflu-
 ent flow control valve; one effluent flow indicator for local mounting; and one
 effluent flow orifice with flanges.

CHEMICAL FEED EQUIPMENT
 The plant manufacturer shall provide equipment for mixing and feeding of
 aluminum sulfate, a polyelectrolyte coagulant aid, and soda ash, as shown on
 the drawings. This chemical feed equipment shall include mix tank, pump, and
 mixer. The polyelectrolyte system shall include a disperser mounted on the mix
 tank.

ELECTRICAL REQUIREMENTS
 The plant control panel shall be provided with a 120 volt, 60 hz, single phase
 power, 50 amp circuit.

Pump motors shall be open drip-proof, either 120 volt, 60 hz, single phase or
 220 volt, 60 hz, three phase, with 40 degree rise rating. Chemical feed pump
 motors shall be 120 volt, 60 hz, single phase. Motor starters, as required, shall
 be provided by the contractor and mounted as shown on the plans.

All electrical connections between components shall be provided and installed
 by the contractor.

VALVES AND PIPING
 The contractor shall furnish and install all interconnecting piping and wiring
 and valves not furnished by the plant supplier as shown on the plans. This sec-
 tion to include couplings, check valves, isolation valves, and all other manual
 valves for pneumatic or hydraulic service for plant control.

PNEUMATIC REQUIREMENTS (SWB-150, SWB-250 ONLY)
 The contractor shall provide a dry instrument air compressor system capable
 of providing 3 scfm at 80 psig. Equipment to include compressor, receiver, and
 dryer. The system shall be located as shown on the plans. All pneumatic con-
 nections shall be provided and installed by the contractor.

PLANT STARTUP AND OPERATOR TRAINING
 The treatment plant manufacturer shall provide for 5 days of plant startup and
 operator training to include placement direction of the filter media, plant check-
 out, and operator instruction.

OPERATOR'S MANUAL
 There shall be furnished with the plant two manuals which shall provide com-
 plete instructions for installation, startup, operation, and maintenance.

DRAWINGS
 Two sets of drawings shall be provided by the treatment plant manufacturer
 showing the dimensions of all interconnecting piping and plant flow scheme for
 the contractor's use.

CASE HISTORIES

RICHFIELD SPRINGS, NEW YORK

PLANT SIZE: 0.3 MGD
ENGINEER: Standard Engineering
 Albany, New York
STARTUP: February, 1973
EQUIPMENT: Two Recla-Mate SWB-250's

COMMENTS: Richfield Springs is a ski resort area which experiences wide variations in waste stream flow and strength due to seasonal population growth. The processes selected for treatment of this variable stream are a two-stage lagoon treatment using diffused aeration followed by two SWB-150's. The second stage lagoon accomplishes nitrification in the system.

The two SWB's operate at a constant rate of 110 gpm and incorporate coagulation, flocculation, tube settling, and mixed-media filtration. Alum and polyelectrolyte are used as coagulants. The mixed-media filters operate at 5 gpm per square foot. All plant functions are automatic.

Plant operating data are given below: Waste Quality Characteristics

	Lagoon Effluent		Filter Effluent		Filter Performance	
	mg/l		mg/l		Run Length	4-5 hours
COD	54-94		23-34		Filter Rate	4 gpm/ft ²
BOD	15-29		4.2-4.5		Backwash Usage	11-17 percent
SS	31-46		7.5-14		Settled Sludge	1-2 percent
Total P	1.26-2.34		0.01-0.04		Dewatered Sludge	13 percent
Turbidity	34-61		0.9-3.5			
Coliform	31,000-34,000 MPN		20-11,100 MPN			