



MUNICIPAL WATER USE INSPECTION FORM

DATE: AUGUST 22, 2000 COMPANY REP.: ALBERT PULLEN - HAMLET SAO

LICENSEE: HAMLET OF PAULATUK LICENCE #: N7L3-1619

WATER SUPPLY

Source (s): NEW WATER LAKE Quantity Used (to date): UNKNOWN
Owner/Operator: HAMLET (estimate or actual)

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable

Intake Facilities: A Storage Structure N/A Treatment Systems A Chem. Storage A

Flow Meas. Device A Convey. Lines N/A Pumping Stations A

Comments: NO PROBLEMS NOTED WITH WATER SUPPLY.

WASTE DISPOSAL

Sewage Sewage Treatment System (primary, secondary or tertiary) PRIMARY

Natural Water body Continuous Discharge (land or water) _____

Seasonal Discharge PEAK RUN-OFF Wetlands Treatment Trench _____

Solid Waste: Owner/Operator: HAMLET

Landfill _____ Burn & Landfill Other _____

Indicate: A - Acceptable U - Unacceptable N/A - Not Applicable

Disch. Quality A Decant Structure N/A Erosion U - @ OLD SWDS AT SHORE

Disch. Meas. Dev. N/A Dyke Inspection N/A Seepages N/A

Dams, Dykes N/A Freeboard A Spills NONE REPORTED.

Construction A - NEW CONCRETE CELL O & M Plan N/A A & R Plan N/A

Periods of Discharge: PEAK RUN-OFF HIGH PRECIPITATION Effluent Discharge Rate: NATURAL OUTFLOW

Comments: _____

NEW FENCING AROUND CURRENT SWDS. INITIAL CELLS STILL FULL OF WATER BUT NOT USED.

NO DEAD ANIMAL PIT. BURNING DONE IN ACTIVE CELL. NOT MUCH SEGREGATION.

SOME EROSION AT ABANDONED SWDS. VERY LITTLE WIND BLOWN DEBRIS AT SWDS.

FUEL STORAGE Owner: _____ Operator _____ Condition of Tanks _____

Berms & Liners _____ Water within berm: _____ Evidence of Leaks: _____

Drainage Pipes _____ Pump Station and Catchment Berm _____

Pipeline Condition _____ Not Applicable: _____

SURVEILLANCE NETWORK PROGRAM

Samples Collected: (Hamlet) NONE

(DIAND) TAKEN AT SNP 1619-1 AND SNP 1619-2.

Signs Posted: SNP SNP STATIONS NOT POSTED Warning YES.

Record & Reporting ACCEPTABLE.

Geotechnical Inspection: N/A

Compliance of Act or Licence: NONE NOTED AT TIME OF INSPECTION.

Page 2 attached Yes _____ No X

Senior Administrative Officer
Licensee Representatives Title

Albert Pullen
Licensee Representatives Signature

SCOTT GALLAGHER - WATER RESOURCES OFFICER
Inspector's Name

[Signature]
Inspector's Signature