

COPY	
BOARD.	5
G.W.	1
E.A.	1
W. RES.	ORG
File-	0162/1779/1769

Attention: **Gord Wray, Gordon**

Date: 2/28/02

Company: NWT WATER BOARD

Number of Pages: 4

Fax Number: 18676692719

Voice Number:

From: **Michael Fabijan**

Company: Kavik-AXYS Inc.

Fax Number: (867) 777-4925

Voice Number: (867) 777-4548



Subject: Re: Sampling results

**Comments:**

Dear Mr. Wray

Please find attached the January 2002 analysis results for waste water samples from the Japex Mallik, Shell Farewell, and Conoco Weatherhaven Camps.

If you have any questions regarding these results please give me a call.

Sincerely  
Michael Fabijan

**Mallik Camp - Japex**

Licencee:

Licence number:

Station number:

N7L1-1769

1769-1

Current as of 4 pm, 28-Feb-2002

Test	Laboratory Id #	Chlorine residual mg/l	Chlorine total mg/l	pH	TSS mg/l	Ammonia-Nitrogen mg/l	BOD mg/l	Total Phosphorus mg/l	Faecal Coliform CFU/dL	Oil and Grease mg/l
Units		0.01	0.01	0.05	3	0.005	2	0.004	1	0.2
Detection limit		NLL	NLL	6.0 to 9.0	100	NLL	80	NLL	10,000	5.0
Licence maximums										

Date/Time

Sampled

Sample

**Mallik Camp**

06-Jan-02	220118	1 F	<0.01	<0.01	7.56	38	28.500	39	7.69	<10	3.9
		2 F	<0.01	<0.01	7.50	37	30.400	41	7.04	<10	3.0
		Average	<0.01	<0.01	7.53	38	29.450	40	7.37	<10	3.5
17-Jan-02	220168	P			7.49	50	4.430	16		<100	5.5
21-Jan-02	220172	1 F	<0.01	<0.01	7.41	124	6.080	89	7.80	400,000	8.7
		2 F	<0.01	<0.01	7.34	142	5.880	90	8.17	500,000	4.6
		Average	<0.01	<0.01	7.38	133	5.980	90	7.99	450,000	6.7

TSS

BOD

NLL

P

F

QA/QC

NA

= Total Suspended Solids

= Biological Oxygen Demand

= Not listed in licence

= Preliminary analysis results

= Final analysis results

= Quality control samples - blanks

= Results not available