



July 3, 2019

Mayor Ray Ruben
Hamlet of Paulatuk
P.O. Box 98
Paulatuk, NT X0E 1N0

Dear Mayor Ruben:

Re: N7L3-1619 - Hamlet of Paulatuk, Municipal Water Licence - 2018 Annual Report

The Inuvialuit Water Board (IWB) acknowledges receipt of the above-mentioned report received on May 29, 2019. Upon review, information gaps have been identified. As per water licence N7L3-1619, please provide the following additional information:

1. Part B, Item 1 f):
 - Surveillance Network Program (SNP) station numbers 1619-2, 1619-3 and 1619-4 sampling requirements include twice annually - once immediately after break-up and once prior to freeze-up. The Annual Report submission includes laboratory results for samples collected immediately after break-up, but no laboratory results for samples collected immediately prior to freeze-up. As described under water licence Annex A, laboratory results for samples collected immediately prior to freeze-up are also required to be submitted; and
 - Provide tabular summaries of all data generated under the SNP sampling stations 1619-5 (Run-off from existing Solid Waste Disposal Facilities); and 1619-6 (Run-off from existing Solid Waste Disposal Facilities before entering Old Water Lake).
2. Part B, Item 1 n): all correspondence between the inspector and the Licensee.
3. Part B, Item 1 o): any other details on waste disposal requested by the Board by November 1 of the year being reported.

The above-mentioned information is a requirement of annual reporting and a condition of the water licence. The sampling must be completed annually to maintain compliance of your current water licence. The submitted documents, including all related IWB correspondence, will be placed on the IWB Public Register.

Should you have any questions or concerns, please contact me at 867-678-8610 or adhikarib@inuvwb.ca or Mardy Semmler, Executive Director, at 867-678-8609 or semmlerm@inuvwb.ca.

Sincerely,

Bijaya Adhikari, PhD
Science and Regulatory Coordinator

cc: John Holland, SAO - Hamlet of Paulatuk
Lloyd Gruben, ENR Water Resource Officer - Inuvik Region